



- Type, batch or serial number or any other element allowing identification of the product

XSLCY

Range: cross section from 0,50 to 240 mm² / outer diameter from 5,8 to 75,0 mm

Lot number: as indicated on cable, label and delivery note

- Declared performance

Unique identification code	Reaction to fire class	Dangerous substances
XSLCY	Cca - s3, d0, a3	None
Harmonized technical specification EN 50575:2016		

- System of assessment and verification of constancy of performance of the product

System AVCP 1+

- Notified product certification body

LAPI S.p.A. 0987

performed the determination of the product-type, the initial inspection of the manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of FPC, the audit-testing of samples taken before placing the product on the market and publishes the certificate of constancy of performance

0987-CPR-292

- Intended use of the product

CABLES FOR POWER, SIGNALLING AND CONTROL OR DATA TRANSMISSION with the objective of limiting the generating and spread of fire and smoke

- Name of the manufacturer

SPECIALCAVI BALDASSARI SRL

Via G.Pieraccini 76 - 55012 Capannori(LU) - Italy

Tel. +39 0583 935741 Fax 0583 429474 Email: cpr@specialcavibaldassari.it

www.specialcavibaldassari.it/dop

The performance of the product identified above is in conformity with the set of declared performances.
This declaration of performance is issued under the sole responsibility of the manufacturer identified above.

Capannori, 10/11/2022

Signed for and on behalf of the manufacturer by

Marco Baldassari
Chief Executive Officer

